

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	23 - Central Okanagan
School Name:	Mount Boucherie Secondary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-10-01
	Date of next inspection: 2022-02-01
	Date and type of most recent maintenance: 2021-10-01 Filter Change
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: Lowered CO2 setpoint where possible or adjusted the outdoor air damper settings.
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Merv 13 filters installed.
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Building automation control systems are utilized.
Other Relevant Information:	n/a
District Contact for any Questions:	Name:
	Phone Number:
	Email: Operations.Department@sd23.bc.ca